

Notice of a Routine Monitoring Violation for Chlorite

Central Texas Water Supply Corporation PWS#0140161 failed to collect the required daily samples for chlorite monitoring of the water entering the distribution system 8/1/2014 – 10/31/2014.

This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523. Failure to monitor or monitoring inadequately makes it impossible to know if there is chlorite in excess of the maximum contaminant level (MCL) requirement of 1.0 mg/l (ppm). Our water system is required to take one sample each day of the water entering the distribution system.

Failure to collect all required chlorite samples is a violation of the monitoring requirements and we are required to notify you of this violation.

If you have any questions regarding this violation, you may contact **Lee Kelley, General Manager**, at **254-698-2779**.