

## **Section 00 9113 Addendum No. 2**

CONNECTION OF 18 RESIDENTIAL HOMES TO MUNICIPAL WATER  
EAST BAY CHARTER TOWNSHIP, GRAND TRAVERSE COUNTY, MICHIGAN

To all prospective bidders and others concerned, YOU ARE HEREBY ADVISED THAT the Contract Documents for the above referenced Project are revised in the following manner:

### **PROJECT MANUAL**

#### **Section 01 1100 Summary of Work**

- Paragraph 1.01.3, Well Abandonment - Please add the following paragraph at the end:

If the well being abandoned acted as the electrical grounding system for the home, the contractor is to complete needed improvements to ensure the home is grounded as required by local construction codes. Payment for this work is included in the pay item for the connection of the specific address.

- Paragraph 1.01.4, Water Service Leads - Please add the following paragraph at the end:

House 916 Avenue B requires an extra long water service lead. Due to this length, the use of HDPE IPS SDR 9 pipe is allowed, along with Type K copper as already specified. Both HDPE and copper must be 1.5-inch nominal diameter pipe to reduce excessive pressure loss at higher flows.

This Addendum is hereby incorporated into the original Contract Documents for the bidding referred to above and is considered as binding as though originally appearing therein. RECEIPT OF THIS ADDENDUM MUST BE NOTED in the place provided on the Proposal Section 00 4243, Addendum No. 2, dated December 15, 2020.