



VILLAGE OF GLENCOE

FORMS & APPLICATIONS

675 Village Court, Glencoe, Illinois 60022
p: (847) 835-4111 | info@villageofglencoe.org | Follow Us: @VGlencoe

Last Updated: March 23, 2017

www.villageofglencoe.org

Fire Sprinkler Exceptions for New House Permit Submissions

- All new houses that do not have a fire sprinkler system are required to have a wired, low-voltage or 120 volt smoke detector system connected to a private central station alarm monitoring company.
- A whole house fire sprinkler system is not required if dimensional lumber (i.e. 2"x 6", 2"x 8", 3"x 10", or 2"x 12") is used for attic roofs, ceilings and floors.
- A whole house fire sprinkler system is required, if prefabricated roof trusses, floor or ceiling joists are used.