

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
City of Highland Park	City Hall	1st Floor Finance	Sink	7/13/2016	7/25/2016	<5.0 PPB
City of Highland Park	City Hall	1st Floor Main Hallway	Fountain	7/13/2016	7/25/2016	<5.0 PPB
City of Highland Park	City Hall	2nd Floor Mayors Area	Sink	7/13/2016	7/25/2016	<5.0 PPB
City of Highland Park	City Hall	2nd Floor Pre-Session	Sink	7/13/2016	7/25/2016	<5.0 PPB
City of Highland Park	City Hall	Lower Level Cafeteria	Sink	7/13/2016	7/25/2016	<5.0 PPB
City of Highland Park	Firehouse Youth Center	1st Floor Front Entrance	Fountain	7/25/2016	7/29/2016	<5.0 PPB
City of Highland Park	Firehouse Youth Center	1st Floor Kitchen	Sink	7/25/2016	7/29/2016	<5.0 PPB
City of Highland Park	Firehouse Youth Center	Basement	Fountain	7/25/2016	7/29/2016	<5.0 PPB
City of Highland Park	Highland Park Main (Central)Train Station	Coffee Shop	Sink	7/19/2016	7/25/2016	<5.0 PPB
City of Highland Park	Highland Park Main (Central)Train Station	Main Lobby	Fountain	7/19/2016	7/25/2016	<5.0 PPB
City of Highland Park	Highland Park Main (Central)Train Station	Ticket Window	Sink	7/20/2016	7/25/2016	<5.0 PPB
City of Highland Park	Karger Center	Upstairs Men's Restroom	Sink	8/22/2016	9/13/2016	49.0 PPB
City of Highland Park	Karger Center	Upstairs Women's Restroom	Sink	8/22/2016	9/13/2016	118.0 PPB
City of Highland Park	Karger Center	Yellow Room Restroom	Sink	8/22/2016	9/13/2016	10.0 PPB
City of Highland Park	Karger Center	Upstairs Women's Restroom	Sink	7/28/2016	7/29/2016	7.0 PPB
City of Highland Park	Karger Center	Upstairs By Front Door	Fountain	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Yellow Room Classroom	Sink	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Yellow Room Restroom	Sink	7/28/2016	7/29/2016	6.0 PPB
City of Highland Park	Karger Center	Blue Room Classroom	Sink	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Green Room Classroom	Sink	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Green Room Restroom	Sink	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Outside By Gate	Fountain	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Lower Level Kitchen	Sink	7/26/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Lower Level Mens Locker Room	Sink	7/26/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Main Level Hallway	Fountain	7/26/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Lower Level, North Main Hall, East End of Hallway	Fountain	7/26/2016	7/29/2016	7.0 PPB
City of Highland Park	Karger Center	Lower Level Women's Restroom	Sink	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Karger Center	Upstairs Men's Restroom	Sink	7/28/2016	7/29/2016	21.0 PPB
City of Highland Park	Karger Center	Lower Level East Hall Outside Gym at Women's Restroom	Fountain	9/2/2016	9/13/2016	6.0 PPB
City of Highland Park	Main Fire Station #33	Bunk Area Office	Fountain	8/5/2016	8/11/2016	<5.0 PPB
City of Highland Park	Main Fire Station #33	Fitness Center	Fountain	8/5/2016	8/11/2016	<5.0 PPB
City of Highland Park	Main Fire Station #33	Front Lobby Break Room	Sink	8/5/2016	8/11/2016	<5.0 PPB
City of Highland Park	Main Fire Station #33	Kitchen Area Bunk Room	Sink	8/5/2016	8/11/2016	<5.0 PPB
City of Highland Park	North Fire Station #34	Kitchen	Sink	8/5/2016	8/11/2016	<5.0 PPB
City of Highland Park	Police Department	1st Floor Cafeteria	Sink	7/27/2016	7/29/2016	<5.0 PPB
City of Highland Park	Police Department	1st Floor Dispatch	Sink	7/27/2016	7/29/2016	<5.0 PPB
City of Highland Park	Police Department	1st Floor Evidence Processing	Sink	7/27/2016	7/29/2016	<5.0 PPB
City of Highland Park	Police Department	1st Floor Front Hallway	Fountain	7/27/2016	7/29/2016	<5.0 PPB
City of Highland Park	Police Department	1st Floor Lockup	Sink	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Police Department	2nd Floor Chiefs Area	Sink	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Police Department	2nd Floor Front Hallway	Fountain	7/28/2016	7/29/2016	<5.0 PPB
City of Highland Park	Public Services Building	1st Floor Front Reception Area	Fountain	7/7/2016	7/8/2016	<5.0 PPB
City of Highland Park	Public Services Building	Cafeteria 1st Floor	Sink	7/7/2016	7/8/2016	<5.0 PPB
City of Highland Park	Public Services Building	2nd Floor Cofffee Station	Sink	7/7/2016	7/8/2016	<5.0 PPB
City of Highland Park	Public Services Building	2nd Floor Rear Hall Way	Fountain	7/7/2016	7/8/2016	<5.0 PPB
City of Highland Park	Public Services Building	Garage	Fountain	7/7/2016	7/8/2016	<5.0 PPB

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
City of Highland Park	Ravinia Fire Station #32	Kitchen	Sink	8/5/2016	8/11/2016	8.0 PPB
City of Highland Park	Ravinia Train Station	Near Restrooms	Fountain	7/26/2016	7/29/2016	<5.0 PPB
City of Highland Park	Senior Center	Kitchen	Sink	7/12/2016	7/29/2016	<5.0 PPB
City of Highland Park	Water Treatment Plant	Lunch Room	Sink	7/6/2016	7/8/2016	<5.0 PPB
City of Highland Park	Water Treatment Plant	Pump Room	Fountain	7/6/2016	7/8/2016	<5.0 PPB
City of Highland Park	Water Treatment Plant	Office hallway	Fountain	7/6/2016	7/8/2016	<5.0 PPB
City of Highland Park	Water Treatment Plant	Office hallway- kitchenette	Sink	7/6/2016	7/8/2016	<5.0 PPB
Park District of Highland Park	Brown Park	Tennis Courts 4M33.1	Outdoor Fountain #1	8/12/2016	8/19/2016	37.0 PPB
Park District of Highland Park	Brown Park	Tennis Courts 4M33.1	Outdoor Fountain #2	8/12/2016	8/19/2016	25.0 PPB
Park District of Highland Park	Carroll Snyder Park	Playground 4L33.1	Outdoor Fountain #1-Upper	8/12/2016	8/23/2016	<5.0 PPB
Park District of Highland Park	Carroll Snyder Park	Playground 4L33.1	Outdoor Fountain #2-Lower	8/12/2016	8/23/2016	<5.0 PPB
Park District of Highland Park	Centennial Park Rink	Vending Machines - Rink Area	Indoor Fountain	8/10/2016	8/16/2016	<5.0 PPB
Park District of Highland Park	Centennial Park Rink	By Restroom	Indoor Fountain	8/10/2016	8/16/2016	<5.0 PPB
Park District of Highland Park	Centennial Park Rink	Locker Room A	Sink	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Centennial Park Rink	Locker Room B	Sink	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Centennial Park Rink	Locker Room C	Sink	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Centennial Park Rink	Locker Room D	Sink	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Centennial Park Rink	Activity Room	Sink	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Central Park	Playground	Fountain #1-Upper	8/10/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Central Park	Playground	Fountain #2-Lower	8/10/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Cloverdale Park	Tennis Courts 2E33.1	Outdoor Fountain	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Danny Cunniff Park	Athletic field shelter 1D33.1	Outdoor Fountain #1	8/10/2016	8/16/2016	<5.0 PPB
Park District of Highland Park	Danny Cunniff Park	Centennial 1D33.2	Outdoor Fountain #1	8/10/2016	8/16/2016	<5.0 PPB
Park District of Highland Park	Danny Cunniff Park	Centennial 1D33.3	Outdoor Fountain #2	8/10/2016	8/16/2016	<5.0 PPB
Park District of Highland Park	Danny Cunniff Park	Playgrounds 1D33.3	Outdoor Fountain #1	8/10/2016	8/16/2016	<5.0 PPB
Park District of Highland Park	Danny Cunniff Park	Playgrounds 1D33.4	Outdoor Fountain #2	8/10/2016	8/16/2016	<5.0 PPB
Park District of Highland Park	Danny Cunniff Park	Tennis Courts 1D33.4	Outdoor Fountain #1	8/10/2016	8/16/2016	<5.0 PPB
Park District of Highland Park	Danny Cunniff Park	Tennis Courts 1D33.5	Outdoor Fountain #2	8/10/2016	8/16/2016	<5.0 PPB
Park District of Highland Park	Deer Creek	Front Lobby	Indoor Fountain	8/3/2016	8/5/2016	<5.0 PPB
Park District of Highland Park	Deer Creek	Lower Level Hallway	Indoor Fountain	8/3/2016	8/11/2016	<5.0 PPB
Park District of Highland Park	Deer Creek	Lower Lobby - outside locker rooms	Indoor Fountain	8/3/2016	8/8/2016	<5.0 PPB
Park District of Highland Park	Founders	Along St. Johns	Outdoor Fountain #1	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Founders	Along St. Johns	Outdoor Fountain #2	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Heller Nature Center	Main Bldg Classroom	Water Line for Sink	8/29/2016	9/13/2016	78.0 PPB
Park District of Highland Park	Heller Nature Center	Exterior - S. side@ front lawn	Outdoor Fountain #1	8/10/2016	8/15/2016	<5.0 PPB
Park District of Highland Park	Heller Nature Center	Exterior - S. side@ front lawn	Outdoor Fountain #2	8/10/2016	8/15/2016	<5.0 PPB
Park District of Highland Park	Heller Nature Center	Main Building - N. lobby wall near desk	Indoor Fountain #1	8/10/2016	8/15/2016	<5.0 PPB
Park District of Highland Park	Heller Nature Center	Main Building - N. lobby wall near desk	Indoor Fountain #2	8/10/2016	8/15/2016	<5.0 PPB
Park District of Highland Park	Heller Nature Center	Main Bldg Classroom	Sink	8/10/2016	8/15/2016	23.0 PPB
Park District of Highland Park	Heller Nature Center	Main Bldg Kitchen	Sink	8/10/2016	8/15/2016	<5.0 PPB
Park District of Highland Park	Heller Nature Center	Garage	Sink	8/10/2016	8/15/2016	<5.0 PPB
Park District of Highland Park	Heller Nature Center	Out Bldg Classroom	Sink	8/10/2016	8/15/2016	<5.0 PPB
Park District of Highland Park	Hidden Creek	Exterior	Splash Pad	8/5/2016	8/11/2016	<5.0 PPB
Park District of Highland Park	Hidden Creek	Concession Stand	Sink (North)	8/5/2016	8/11/2016	<5.0 PPB
Park District of Highland Park	Hidden Creek	Concession Stand	Sink (South)	8/5/2016	8/11/2016	<5.0 PPB
Park District of Highland Park	Jens Jensen Park	Along Roger Williams	Outdoor Fountain #1-Upper	8/12/2016	8/19/2016	5.0 PPB

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
Park District of Highland Park	Jens Jensen Park	Along Roger Williams	Outdoor Fountain #2-Lower	8/12/2016	8/19/2016	5.0 PPB
Park District of Highland Park	Larry Fink Memorial Park	Baseball Field 3I33.1	Outdoor Fountain #1-Upper	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Larry Fink Memorial Park	Baseball Field 3I33.2	Outdoor Fountain #2-Lower	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Larry Fink Memorial Park	Dog Park 3I33.2	Outdoor Fountain #1-Upper	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Larry Fink Memorial Park	Dog Park 3I33.3	Outdoor Fountain #2-Lower	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Larry Fink Memorial Park	Dog Park 3I33.4	Outdoor Fountain #3-Dog Bowl	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Larry Fink Memorial Park	Playground 3I33.3	Outdoor Fountain #1-Upper	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Larry Fink Memorial Park	Playground 3I33.4	Outdoor Fountain #2-Lower	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Laurel Park and Rose Garden	Sheridan Rd. 4F33.1	Outdoor Fountain	8/10/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Lincoln Park	W. Baseball field @ Lincoln Ave. 4G33.1	Outdoor Fountain	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Lincoln Park	Building near basketball court	Inside Fountain	8/12/2016	8/23/2016	<5.0 PPB
Park District of Highland Park	Memorial Park	Linden Ave. East of Gazebo 4E33.1	Outdoor Fountain #1-Upper	8/10/2016	8/18/2016	18.0 PPB
Park District of Highland Park	Memorial Park	Linden Ave. East of Gazebo 4E33.2	Outdoor Fountain #2-Lower	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Mooney Park	Baseball Field 2G33.1	Outdoor Fountain #1-Upper	8/18/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Mooney Park	Baseball Field 2G33.2	Outdoor Fountain #2-Lower	8/18/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Mooney Park	Basketball Court 2G33.2	Outdoor Fountain #1-Upper	8/18/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Mooney Park	Basketball Court 2G33.3	Outdoor Fountain #2-Lower	8/18/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Moraine Park	Bathroom Building 4B33.1	Outdoor Fountain #1-Upper	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Moraine Park	Bathroom Building 4B33.2	Outdoor Fountain #2-Lower	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Moroney Park	Entrance of the tot lot 4J33.1	Outdoor Fountain #1-Upper	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Moroney Park	Entrance of the tot lot 4J33.2	Outdoor Fountain #2-Lower	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Old Elm Park	Bathroom Building 1C33.1	Outdoor Fountain #1-Upper	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Old Elm Park	Bathroom Building 1C33.2	Outdoor Fountain #2-Lower	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Olson Park	Playground 2C33.1	Outdoor Fountain #1-Upper	8/18/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Olson Park	Playground 2C33.2	Outdoor Fountain #2-Lower	8/18/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Olson Park	Playground 2C33.3	Outdoor Fountain #3-Dog Bowl	8/18/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Park Ave.	Yacht Club - Exterior, attached to shower	Outdoor Fountain	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Park Ave.	Yacht Club - Exterior, north of building	Outdoor Fountain	8/10/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Park Ave.	Yacht Club	Indoor Fountain	8/10/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Port Clinton	Central path 4A33.1	Outdoor Fountain #1	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Port Clinton	Central path 4A33.2	Outdoor Fountain #2	8/10/2016	8/18/2016	7.0 PPB
Park District of Highland Park	Recreation Center	Lower Level @ mens locker room	Indoor Fountain #1-Upper	8/15/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Recreation Center	Lower Level @ mens locker room	Indoor Fountain #2-Lower	8/15/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Recreation Center	Lower Level @ Pool Deck - N. wall	Indoor Fountain #2-Upper	8/15/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Recreation Center	Lower Level Lobby By bathrooms	Indoor Fountain	8/15/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Recreation Center	Upper Level @ Cycle Studio between the bathrooms	Indoor Fountain #1-Upper	8/15/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Recreation Center	Upper Level @ Cycle Studio between the bathrooms	Indoor Fountain #2-Lower	8/15/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Recreation Center	Upper Level @ Kid Fit - long corridor wall	Indoor Fountain	8/15/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Recreation Center	Upper Level Fitness Floor - By bathrooms	Indoor Fountain #1-Upper	8/15/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Recreation Center	Upper Level Fitness Floor - By bathrooms	Indoor Fountain #2-Lower	8/15/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Rory David Deutsch Tot Lot	Entrance 3E33.1	Outdoor Fountain #1-Upper	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Rory David Deutsch Tot Lot	Entrance 3E33.2	Outdoor Fountain #2-Lower	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Rosewood Beach	Along the boardwalk 4Pa33.1	Outdoor Fountain #1	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Rosewood Beach	Along the boardwalk 4Pa33.2	Outdoor Fountain #2	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Rosewood Beach	Along the boardwalk 4Pa33.3	Outdoor Fountain #3	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Rosewood Beach	Interpretive Center Interior - By restrooms	Indoor Fountain #1	8/10/2016	8/18/2016	<5.0 PPB

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
Park District of Highland Park	Rosewood Beach	Interpretive Center Interior - By restrooms	Indoor Fountain #2	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Rosewood Park	4P33.1	Outdoor Fountain	8/10/2016	8/18/2016	<5.0 PPB
Park District of Highland Park	Sherwood Park	South edge of the park 2F33.1	Outdoor Fountain #1-Upper	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sherwood Park	South edge of the park 2F33.2	Outdoor Fountain #2-Lower	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Valley Golf Course	Clubhouse Snack Bar/Grill	Kitchen sink - South	8/5/2016	8/11/2016	<5.0 PPB
Park District of Highland Park	Sunset Valley Golf Course	Clubhouse across from Janitor Closet	Fountain	8/5/2016	8/11/2016	<5.0 PPB
Park District of Highland Park	Sunset Valley Golf Course	Parks Dept. lower level storage	Slop Sink-Eyewash	8/5/2016	8/11/2016	<5.0 PPB
Park District of Highland Park	Sunset Valley Golf Course	Parks Dept.	Office Sink	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Sunset Valley Golf Course	Parks Dept.	Breakroom Sink	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Planning Office Upstairs Kitchen	Sink	8/5/2016	8/11/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Basketball Court 3D33.1	Outdoor Fountain	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Near Planning office 3D33.2	Outdoor Fountain #1-Upper	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Near Planning office 3D33.3	Outdoor Fountain #2-Lower	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	N. side of park 3D33.3	Outdoor Fountain	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Playgrounds 3D33.4	Outdoor Fountain #1-Upper	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Playgrounds 3D33.5	Outdoor Fountain #2-Lower	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Tennis Courts 3D33.5	Outdoor Fountain #1-Upper	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Warming Room	Indoor Fountain	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Tennis Courts 3D33.5	Outdoor Fountain #2-Lower	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Sunset Woods Park	Baseball at south end of park	Outdoor Fountain	8/16/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	West Ridge	South hall - Opposite dance	Water Line for Fountain #1-East	8/24/2016	9/2/2016	20.0 PPB
Park District of Highland Park	West Ridge	South hall - Opposite dance	Water Line for Fountain #2-West	8/24/2016	9/13/2016	68.0 PPB
Park District of Highland Park	West Ridge	South hall -Opposite Ryca's Office	Water Line for Fountain #1-East	8/24/2016	9/14/2016	171.0 PPB
Park District of Highland Park	West Ridge	South hall - Opposite Ryca's Office	Water Line for Fountain #2-West	8/24/2016	9/2/2016	<5.0 PPB
Park District of Highland Park	West Ridge	East hall - N. of Kitchen	Indoor Fountain	8/3/2016	8/5/2016	<5.0 PPB
Park District of Highland Park	West Ridge	East hall - Opposite ceramics studio	Indoor Fountain	8/3/2016	8/5/2016	<5.0 PPB
Park District of Highland Park	West Ridge	South hall - Opposite dance	Indoor Fountain #1-East	8/3/2016	8/8/2016	59.0 PPB
Park District of Highland Park	West Ridge	South hall - Opposite dance	Indoor Fountain #2-West	8/3/2016	8/9/2016	42.0 PPB
Park District of Highland Park	West Ridge	South hall -Opposite Ryca's Office	Indoor Fountain #1-East	8/3/2016	8/9/2016	38.0 PPB
Park District of Highland Park	West Ridge	South hall - Opposite Ryca's Office	Indoor Fountain #2-West	8/3/2016	8/9/2016	40.0 PPB
Park District of Highland Park	West Ridge	Outside Noel Rolle's Office	Water Cooler	8/3/2016	8/5/2016	<5.0 PPB
Park District of Highland Park	West Ridge	Kitchen	Sink	8/3/2016	8/5/2016	<5.0 PPB
Park District of Highland Park	West Ridge	Jammin Jungle	Indoor Fountain	8/3/2016	8/5/2016	<5.0 PPB
Park District of Highland Park	West Ridge Park	E. Side of athletic fields	Outdoor Fountain	8/12/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	West Ridge Park	W. Side of athletic fields	Outdoor Fountain #1-Upper	8/12/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	West Ridge Park	W. Side of athletic fields	Outdoor Fountain #2-Lower	8/12/2016	8/22/2016	<5.0 PPB
Park District of Highland Park	Woodridge Park	Near Tennis 2M33.1	Outdoor Fountain #1	8/12/2016	8/19/2016	<5.0 PPB
Park District of Highland Park	Woodridge Park	Near Tennis 2M33.2	Outdoor Fountain #2	8/12/2016	8/19/2016	<5.0 PPB
Public Library	Public Library	Upper Level Restroom	Sink	7/28/2016	7/29/2016	97.0 PPB
Public Library	Public Library	1st Floor by Public Restrooms	Indoor Fountain #1	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	1st Floor by Public Restrooms	Indoor Fountain #2	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	1st Floor Director's Office	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	1st Floor Circulation Workroom	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	1st Floor Youth Workroom	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	Lower Level Meeting Room Kitchen	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	Lower Level Tech Services	Sink	7/18/2016	7/25/2016	<5.0 PPB

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
Public Library	Public Library	Lower Level Staff Lounge	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	Lower Level Staff Restroom (Men)	Sink #1	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	Lower Level Staff Restroom (Men)	Sink #2	7/18/2016	7/25/2016	10.0 PPB
Public Library	Public Library	Lower Level Staff Restroom (Women)	Sink #1	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	Lower Level Staff Restroom (Women)	Sink #2	7/18/2016	7/25/2016	9.0 PPB
Public Library	Public Library	Lower Level Staff Restroom (Handicapped)	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	Lower Level Restroom in Meeting Room	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	1st Floor Public Restroom (Men)	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	1st Floor Public Restroom (Women)	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	1st Floor Youth Restroom (Female)	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	1st Floor Youth Restroom (Male)	Sink	7/18/2016	7/25/2016	<5.0 PPB
Public Library	Public Library	Upper Level Restroom	Sink	7/18/2016	7/25/2016	87.0 PPB
Public Library	Public Library	1st Floor Public Keurig Coffee Area	Sink	8/18/2016	8/19/2016	<5.0 PPB
School District 112	Braeside School	Outside RM 102/	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Outside RM 102/	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Outside RM 107 / RM 110	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Outside RM 107 / RM 110	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Outside Washrooms NW hallway	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Outside Washrooms NW hallway	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Room 109B Teachers lounge	Sink-Draw #1	8/9/2016	8/16/2016	20.0 PPB
School District 112	Braeside School	Room 109B Teachers lounge	Sink-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Room 116 Nurses office	Sink-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Room 116 Nurses office	Sink-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Room 4 lower level	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Room 4 lower level	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Outside	Fountain-Draw #1	8/9/2016	8/18/2016	<5.0 PPB
School District 112	Braeside School	Outside	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Door #4	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Braeside School	Door #4	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Across RM 302	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Across RM 302	Fountain-Draw #2	8/9/2016	8/16/2016	5.0 PPB
School District 112	Edgewood Middle School	Across RM 314	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Across RM 314	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Boys Locker RM 134 gym	Fountain-Draw #1	8/9/2016	8/18/2016	52.0 PPB
School District 112	Edgewood Middle School	Boys Locker RM 134 gym	Fountain-Draw #2	8/9/2016	8/18/2016	29.0 PPB
School District 112	Edgewood Middle School	Girls Locker Rm 134 Gym	Fountain-Draw #1	8/9/2016	8/23/2016	153.0 PPB
School District 112	Edgewood Middle School	Girls Locker Rm 134 Gym	Fountain-Draw #2	8/9/2016	8/16/2016	10.0 PPB
School District 112	Edgewood Middle School	Next to RM 209	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Next to RM 209	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Next to RM 211	Fountain-Draw #1	8/9/2016	8/16/2016	11.0 PPB
School District 112	Edgewood Middle School	Next to RM 211	Fountain-Draw #2	8/9/2016	8/16/2016	5.0 PPB
School District 112	Edgewood Middle School	Outside RM 129	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Outside RM 129	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Outside RM 204	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Outside RM 204	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Outside RM 213	Fountain-Draw #1	8/9/2016	8/16/2016	<5.0 PPB

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 112	Edgewood Middle School	Outside RM 213	Fountain-Draw #2	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Outside Washrooms East 3rd Floor	Fountain-Draw #1	8/9/2016	8/16/2016	8.0 PPB
School District 112	Edgewood Middle School	Outside Washrooms East 3rd Floor	Fountain-Draw #2	8/9/2016	8/16/2016	7.0 PPB
School District 112	Edgewood Middle School	Stairs NE corner lower level	Fountain-Draw #1	8/9/2016	8/16/2016	16.0 PPB
School District 112	Edgewood Middle School	Stairs NE corner lower level	Fountain-Draw #2	8/9/2016	8/16/2016	8.0 PPB
School District 112	Edgewood Middle School	Teacher's Lounge	Sink-Draw #1	8/9/2016	8/16/2016	<5.0 PPB
School District 112	Edgewood Middle School	Teacher's Lounge	Sink-Draw #2	8/9/2016	8/25/2016	<5.0 PPB
School District 112	Edgewood Middle School	Café	Fountain-Draw #1	8/9/2016	8/16/2016	7.0 PPB
School District 112	Edgewood Middle School	Café	Fountain-Draw #2	8/9/2016	8/16/2016	5.0 PPB
School District 112	Elm Place Middle School	Across RM 11	Fountain-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Across RM 11	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Across RM 201	Fountain-Draw #1	8/4/2016	8/11/2016	6.0 PPB
School District 112	Elm Place Middle School	Across RM 201	Fountain-Draw #2	8/4/2016	8/11/2016	6.0 PPB
School District 112	Elm Place Middle School	Across RM 209, West	Fountain-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Across RM 209, West	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Boys Locker RM 5	Fountain-Draw #1	8/4/2016	8/11/2016	25.0 PPB
School District 112	Elm Place Middle School	Boys Locker RM 5	Fountain-Draw #2	8/4/2016	8/11/2016	10.0 PPB
School District 112	Elm Place Middle School	Gym RM 6, West	Fountain-Draw #1	8/4/2016	8/11/2016	10.0 PPB
School District 112	Elm Place Middle School	Gym RM 6, West	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Outside RM 103	Fountain-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Outside RM 103	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Outside RM 116	Fountain-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Outside RM 116	Fountain-Draw #2	8/4/2016	8/11/2016	9.0 PPB
School District 112	Elm Place Middle School	Outside RM 123	Fountain-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Outside RM 123	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Outside RM 216	Fountain-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Outside RM 216	Fountain-Draw #2	8/4/2016	8/11/2016	7.0 PPB
School District 112	Elm Place Middle School	RM 10	Sink-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	RM 10	Sink-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	RM 203	Sink-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	RM 203	Sink-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	RM 7 Cafeteria	Fountain-Draw #1	8/4/2016	8/11/2016	8.0 PPB
School District 112	Elm Place Middle School	RM 7 Cafeteria	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Gym RM 6 East Side	Fountain-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Gym RM 6 East Side	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Elm Place Middle School	Opposite Room 209	Fountain-Draw #1	8/4/2016	8/11/2016	8.0 PPB
School District 112	Elm Place Middle School	Opposite Room 209	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Green Bay Early Childhood Center	Across RM 135	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Green Bay Early Childhood Center	Across RM 135	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Green Bay Early Childhood Center	Outside RM 105	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Green Bay Early Childhood Center	Outside RM 105	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Green Bay Early Childhood Center	Outside RM 203	Fountain-Draw #1	8/4/2016	8/9/2016	5.0 PPB
School District 112	Green Bay Early Childhood Center	Outside RM 203	Fountain-Draw #2	8/4/2016	8/9/2016	5.0 PPB
School District 112	Green Bay Early Childhood Center	RM 108	Sink-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Green Bay Early Childhood Center	RM 108	Sink-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Indian Trail School	Outside RM 123	Fountain-Draw #1	8/2/2016	8/11/2016	<5.0 PPB

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 112	Indian Trail School	Outside RM 123	Fountain-Draw #2	8/2/2016	8/11/2016	<5.0 PPB
School District 112	Indian Trail School	Outside RM 136	Fountain-Draw #1	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Indian Trail School	Outside RM 136	Fountain-Draw #2	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Indian Trail School	Big Gym	Fountain - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Big Gym	Fountain - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Outside RM 120	Fountain-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Outside RM 120	Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Outside RM 220	Fountain-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Outside RM 220	Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Small Gym Kitchen	Sink - Draw #1	8/2/2016	8/9/2016	<5.0 PPB
School District 112	Indian Trail School	Small Gym Kitchen	Sink - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Room 148 Conference Room	Sink - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Room 148 Conference Room	Sink - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Teacher's Lounge by Library	Sink - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Teacher's Lounge by Library	Sink - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Downstairs Lunchroom	Fountain Portion - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Downstairs Lunchroom	Fountain Portion - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Outside RM 105	Fountain-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Outside RM 105	Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Staff Workroom Library	Fountain - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Indian Trail School	Staff Workroom Library	Fountain - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Across RM 107	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Across RM 107	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 001	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 001	Fountain-Draw #2	8/4/2016	8/11/2016	25.0 PPB
School District 112	Lincoln Elementray School	Outside RM 108	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 108	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 117	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 117	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 122	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 122	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 201	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 201	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 207	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 207	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 210	Fountain-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Lincoln Elementray School	Outside RM 210	Fountain-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Lincoln Elementray School	RM 104	Sink-Draw #1	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Lincoln Elementray School	RM 104	Sink-Draw #2	8/4/2016	8/11/2016	<5.0 PPB
School District 112	Maintenance Facility	Office kitchen	Sink-Draw #1	8/12/2016	8/19/2016	<5.0 PPB
School District 112	Maintenance Facility	Office kitchen	Sink-Draw #2	8/12/2016	8/19/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 1 (2)	Fountain-Draw #1	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 1 (2)	Fountain-Draw #2	8/2/2016	8/8/2016	12.0 PPB
School District 112	Northwood Junior High School	Outside RM 109	Fountain-Draw #1	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 109	Fountain-Draw #2	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 114C	Fountain-Draw #1	8/2/2016	8/8/2016	<5.0 PPB

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 112	Northwood Junior High School	Outside RM 114C	Fountain-Draw #2	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 121	Fountain-Draw #1	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 121	Fountain-Draw #2	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 129	Fountain-Draw #1	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 129	Fountain-Draw #2	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 131	Fountain-Draw #1	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Outside RM 131	Fountain-Draw #2	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Room 132 (Inside)	North Fountain - Draw #1	8/2/2016	8/9/2016	48.0 PPB
School District 112	Northwood Junior High School	Room 132 (Inside)	North Fountain - Draw #2	8/2/2016	8/9/2016	37.0 PPB
School District 112	Northwood Junior High School	Room 132 (Inside)	South Fountain - Draw #1	8/2/2016	8/9/2016	38.0 PPB
School District 112	Northwood Junior High School	Room 132 (Inside)	South Fountain - Draw #2	8/2/2016	8/9/2016	22.0 PPB
School District 112	Northwood Junior High School	RM 137	Sink-Draw #1	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	RM 137	Sink-Draw #2	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Across RM 144A	Fountain-Draw #1	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Across RM 144A	Fountain-Draw #2	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Northwood Junior High School	Room 134 (Inside Gym)	North Fountain - Draw #1	8/2/2016	8/8/2016	8.0 PPB
School District 112	Northwood Junior High School	Room 134 (Inside Gym)	North Fountain - Draw #2	8/2/2016	8/8/2016	5.0 PPB
School District 112	Northwood Junior High School	Room 134 (Inside Gym)	South Fountain - Draw #1	8/2/2016	8/9/2016	11.0 PPB
School District 112	Northwood Junior High School	Room 134 (Inside Gym)	South Fountain - Draw #2	8/2/2016	8/9/2016	15.0 PPB
School District 112	Oak Terrace Elementary School	Boiler Room	Fountain - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Boiler Room	Fountain - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Outside RM 118	Fountain-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Outside RM 118	Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	MPR Lunch Room Kitchen	Fountain - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	MPR Lunch Room Kitchen	Fountain - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Kitchen	Sink - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Kitchen	Sink - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Teacher's Lounge	Sink - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Teacher's Lounge	Sink - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	RM 160	North Fountain-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	RM 160	North Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Room 106	South Fountain - Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Room 106	South Fountain - Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Outside RM 216	Fountain-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Oak Terrace Elementary School	Outside RM 216	Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 103	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 103	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 107	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 107	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 113	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 113	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 119	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 119	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 123	Fountain-Draw #1	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Ravinia Elementary School	Outside RM 123	Fountain-Draw #2	8/4/2016	8/9/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Across RM 108	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB

**Highland Park
Public Facilities**

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 112	Red Oak Elementary School	Across RM 108	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Outside RM 101	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Outside RM 101	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Inside RM 104F Café	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Inside RM 104F Café	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Outside RM 105	Fountain-Draw #1	8/9/2016	8/15/2016	53.0 PPB
School District 112	Red Oak Elementary School	Outside RM 105	Fountain-Draw #2	8/9/2016	8/15/2016	20.0 PPB
School District 112	Red Oak Elementary School	Inside RM 111	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Inside RM 111	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Outside RM 208F	Fountain-Draw #1	8/9/2016	8/15/2016	20.0 PPB
School District 112	Red Oak Elementary School	Outside RM 208F	Fountain-Draw #2	8/9/2016	8/15/2016	14.0 PPB
School District 112	Red Oak Elementary School	Outsided RM 200	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Outsided RM 200	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Teacher's Lounge	Water Dispenser-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Teacher's Lounge	Water Dispenser-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Outside RM 214	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Red Oak Elementary School	Outside RM 214	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	Across RM 02	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	Across RM 02	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	Across RM 19	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	Across RM 19	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	Across RM 42 / Gym	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	Across RM 42 / Gym	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	Outside RM 18D	Fountain-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	Outside RM 18D	Fountain-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	RM 06	Sink-Draw #1	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Sherwood Elementary School	RM 06	Sink-Draw #2	8/9/2016	8/15/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 202	Fountain-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 202	Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 138	Fountain-Draw #1	8/2/2016	8/8/2016	23.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 138	Fountain-Draw #2	8/2/2016	8/9/2016	32.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 183	Fountain-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 183	Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Rm 180	Sink-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Rm 180	Sink-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 122	Fountain-Draw #1	8/2/2016	8/6/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 122	Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Rm 122	Sink-Draw #1	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Rm 122	Sink-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 112	Fountain-Draw #1	8/2/2016	8/8/2016	<5.0 PPB
School District 112	Wayne Thomas Elementary School	Outside RM 112	Fountain-Draw #2	8/2/2016	8/5/2016	<5.0 PPB
School District 113	Administration Building	AD Building	Sink Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Administration Building	AD Building	Sink Draw #2	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Administration Building	AD Building	Refrigerator Dispenser Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Administration Building	AD Building	Water Cooler Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Administration Building	AD Building	Water Cooler Draw #2	9/7/2016	9/14/2016	<5.0 PPB

**Highland Park
Public Facilities**

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 113	Deerfield High School	Lower level A-Deck by Pool	Fountain A Draw #1-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Lower level A-Deck by Pool	Fountain A Draw #2-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Lower level A-Deck by Pool	Fountain B Draw #1-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Lower level A-Deck by Pool	Fountain B Draw #2-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	New Pool Deck	Fountain A Draw #1-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	New Pool Deck	Fountain A Draw #2-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	New Pool Deck	Fountain B Draw #1-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	New Pool Deck	Fountain B Draw #2-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Warrior Gym	Fountain A Draw #1-West Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Warrior Gym	Fountain A Draw #2-West Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Warrior Gym	Fountain B Draw #1-West Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Warrior Gym	Fountain B Draw #2-West Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Warrior Gym	Fountain C Draw #1-Eaat Upper	8/31/2016	9/13/2016	<5.0 PPB
School District 113	Deerfield High School	Warrior Gym	Fountain C Draw #2-East Upper	8/31/2016	9/13/2016	<5.0 PPB
School District 113	Deerfield High School	Warrior Gym	Fountain D Draw #2-East Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Girls locker room	Fountain Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Girls locker room	Fountain Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Boys locker room	Fountain Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Boys locker room	Fountain Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	I and K Hall	Fountain A Draw #1-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	I and K Hall	Fountain A Draw #2-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	I and K Hall	Fountain B Draw #1-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	I and K Hall	Fountain B Draw #2-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	D Hall near E Hall	Fountain A Draw #1-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	D Hall near E Hall	Fountain A Draw #2-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	D Hall near E Hall	Fountain B Draw #1-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	D Hall near E Hall	Fountain B Draw #2-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	F and G Hall	Fountain A Draw #1-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	F and G Hall	Fountain A Draw #2-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	M and P Hall	Fountain A Draw #1-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	M and P Hall	Fountain A Draw #2-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	M and P Hall	Fountain B Draw #1-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	M and P Hall	Fountain B Draw #2-Lower	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	R-100	Fountain Draw #1	8/31/2016	9/12/2016	<5.0 PPB
School District 113	Deerfield High School	R-100	Fountain Draw #2	8/31/2016	9/12/2016	<5.0 PPB
School District 113	Deerfield High School	R and P Hall	Fountain B Draw #1-Lower	8/31/2016	9/12/2016	<5.0 PPB
School District 113	Deerfield High School	R and P Hall	Fountain B Draw #2-Lower	8/31/2016	9/12/2016	<5.0 PPB
School District 113	Deerfield High School	R-102	Fountain Draw #1	8/31/2016	9/12/2016	<5.0 PPB
School District 113	Deerfield High School	R-102	Fountain Draw #2	8/31/2016	9/12/2016	<5.0 PPB
School District 113	Deerfield High School	R and P Hall	Fountain B Draw #1-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	R and P Hall	Fountain B Draw #2-Upper	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Serving line Café	Fountain Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Serving line Café	Fountain Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Q and exit door 12	Fountain Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Q and exit door 12	Fountain Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Q and E Hall	Fountain A Draw #1	8/31/2016	9/2/2016	<5.0 PPB

**Highland Park
Public Facilities**

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 113	Deerfield High School	Q and E Hall	Fountain A Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Q and E Hall	Fountain B Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Q and E Hall	Fountain B Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	X and F Hall	Fountain A Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	X and F Hall	Fountain A Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	X and F Hall	Fountain B Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	X and F Hall	Fountain B Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	X-215	Fountain A Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	X-215	Fountain A Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	X-215	Fountain B Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	X-215	Fountain B Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Football shed	Fountain Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Football shed	Fountain Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Freshmen Baseball field	Fountain A Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Freshmen Baseball field	Fountain A Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Freshmen Baseball field	Fountain B Draw #1	8/31/2016	9/9/2016	32.0 PPB
School District 113	Deerfield High School	Freshmen Baseball field	Fountain B Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Varsity baseball field dugouts	Fountain A Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Varsity baseball field dugouts	Fountain A Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Varsity baseball field dugouts	Fountain B Draw #1	8/31/2016	9/9/2016	6.0 PPB
School District 113	Deerfield High School	Varsity baseball field dugouts	Fountain B Draw #2	8/31/2016	9/9/2016	7.0 PPB
School District 113	Deerfield High School	K-101	Water Cooler Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	K-101	Water Cooler Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	J-104	Water Cooler Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	J-104	Water Cooler Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	B-110	Water Cooler Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	B-110	Water Cooler Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	E-125	Water Cooler Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	E-125	Water Cooler Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	C-100	Water Cooler Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	C-100	Water Cooler Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	C-100	Ice Machine Melted Ice Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	C-100	Ice Machine Melted Ice Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	F-102	Water Cooler Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	F-102	Water Cooler Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Ice Machine Melted Ice Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Ice Machine Melted Ice Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink A Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink A Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink C Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink C Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink D Draw #1	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink D Draw #2	8/31/2016	9/9/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink E Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink E Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink F Draw #1	8/31/2016	9/2/2016	<5.0 PPB

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 113	Deerfield High School	Kitchen	Sink F Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink G Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Kitchen	Sink G Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	J-108	Sink Draw #1	8/31/2016	9/13/2016	35.0 PPB
School District 113	Deerfield High School	J-108	Sink Draw #2	8/31/2016	9/12/2016	<5.0 PPB
School District 113	Deerfield High School	K-101	Sink Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	K-101	Sink Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	F-102	Sink Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	F-102	Sink Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	X-228	Sink-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	X-228	Sink-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Q-133 Classroom	Sink-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Q-133 Classroom	Sink-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	J-104 Kitchen	Sink-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	J-104 Kitchen	Sink-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Café	Fountain-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Café	Fountain-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Fitness Room	Water Cooler-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Fitness Room	Water Cooler-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Outside West Gym	Fountain-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Outside West Gym	Fountain-Draw #2	8/31/2016	9/13/2016	<5.0 PPB
School District 113	Deerfield High School	New Concession Stand	Hand Sink-Draw #1	8/31/2016	9/2/2016	5.0 PPB
School District 113	Deerfield High School	New Concession Stand	Hand Sink-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	New Concession Stand	Deep Dish Sink-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	New Concession Stand	Deep Dish Sink-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	I-100/104	Water Cooler-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	I-100/104	Water Cooler-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	I-100/104	Sink-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	I-100/104	Sink-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	X-201	Water Cooler-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	X-201	Water Cooler-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Maintenance Break Room	Fountain-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Maintenance Break Room	Fountain-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Maintenance Break Room	Sink-Draw #1	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Maintenance Break Room	Sink-Draw #2	8/31/2016	9/2/2016	<5.0 PPB
School District 113	Deerfield High School	Warrior Gym	Fountain D Draw #1-East Lower	8/31/2016	9/15/2016	<5.0 PPB
School District 113	Highland Park High School	Science area G112	Fountain A Draw #1-Upper	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	Science area G112	Fountain A Draw #2-Upper	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	Science area G112	Fountain B Draw #1-Lower	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	Science area G112	Fountain B Draw #2-Lower	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	G104	Sink Draw #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	G104	Sink Draw #2	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	G102	Ice Machine Melted Ice #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	G102	Ice Machine Melted Ice #2	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	G96	Fountain A Draw #1-Upper	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	G96	Fountain A Draw #2-Upper	9/1/2016	9/12/2016	<5.0 PPB

Highland Park Public Facilities

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 113	Highland Park High School	G96	Fountain B Draw #1-Lower	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	G96	Fountain B Draw #2-Lower	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	G200	Fountain Draw #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	G200	Fountain Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	Auditorium Lobby	Fountain Draw #1	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Auditorium Lobby	Fountain Draw #2	9/1/2016	9/12/2016	40.0 PPB
School District 113	Highland Park High School	Dance Studio	Fountain Draw #1	9/1/2016	9/12/2016	100.0 PPB
School District 113	Highland Park High School	Dance Studio	Fountain Draw #2	9/1/2016	9/12/2016	15.0 PPB
School District 113	Highland Park High School	E119	Fountain A Draw #1-Upper	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	E119	Fountain A Draw #2-Upper	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	E119	Fountain B Draw #1-Lower	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	E119	Fountain B Draw #2-Lower	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	PE area H109	Fountain B Draw #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	PE area H109	Fountain B Draw #2	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	Trainers rm	Ice Machine Melted Ice #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	Trainers rm	Ice Machine Melted Ice #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	Lower Track	Fountain A Draw #1-Lower	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	Lower Track	Fountain A Draw #2-Lower	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	Lower Track	Fountain B Draw #1-Upper	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	Lower Track	Fountain B Draw #2-Upper	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	Café Hall	Fountain A Draw #1	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Café Hall	Fountain A Draw #2	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Café Hall	Fountain B Draw #1	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Café Hall	Fountain B Draw #2	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Faucet A Left Draw #1	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Faucet A Left Draw #2	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Faucet B Right Draw #1	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Faucet B Right Draw #2	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Faucet C Draw #1	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Faucet C Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Faucet D Draw #1	9/1/2016	9/15/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Faucet D Draw #2	9/1/2016	9/15/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Ice Machine Melted Ice #1	9/1/2016	9/15/2016	<5.0 PPB
School District 113	Highland Park High School	Kitchen	Ice Machine Melted Ice #2	9/1/2016	9/15/2016	<5.0 PPB
School District 113	Highland Park High School	A building 3rd FL A342	Fountain Draw #1	9/1/2016	9/15/2016	53.0 PPB
School District 113	Highland Park High School	A building 3rd FL A342	Fountain Draw #2	9/1/2016	9/15/2016	6.0 PPB
School District 113	Highland Park High School	A312	Fountain A Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A312	Fountain A Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A312	Fountain B Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A312	Fountain B Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A311	Sink Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A311	Sink Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A311	Water Cooler Draw #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A311	Water Cooler Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A313	Sink Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A313	Sink Draw #2	9/1/2016	9/13/2016	<5.0 PPB

**Highland Park
Public Facilities**

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 113	Highland Park High School	A313	Water Cooler Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A313	Water Cooler Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	2nd FL A208	Fountain A Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	2nd FL A208	Fountain A Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	2nd FL A208	Fountain B Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	2nd FL A208	Fountain B Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A221	Fountain Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A221	Fountain Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A223	Sink Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A223	Sink Draw #2	9/1/2016	9/14/2016	<5.0 PPB
School District 113	Highland Park High School	A223	Water Cooler Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A223	Water Cooler Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A233	Sink Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A233	Sink Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A233	Water Cooler Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A233	Water Cooler Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	1st FL A130 Nurses office	Sink Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	1st FL A130 Nurses office	Sink Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A130	Water Cooler Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A130	Water Cooler Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A135	Sink Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A135	Sink Draw #2	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A123H	Fountain A Draw #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A123H	Fountain A Draw #2	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A123H	Fountain B Draw #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A123H	Fountain B Draw #2	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A125	Sink Draw #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A125	Sink Draw #2	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A125	Water Cooler Draw #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A125	Water Cooler Draw #2	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A117	Fountain A Draw #1	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A117	Fountain A Draw #2	9/1/2016	9/12/2016	<5.0 PPB
School District 113	Highland Park High School	A117	Fountain B Draw #1	9/1/2016	9/20/2016	<5.0 PPB
School District 113	Highland Park High School	A117	Fountain B Draw #2	9/1/2016	9/20/2016	<5.0 PPB
School District 113	Highland Park High School	A106 teacher café	Water Cooler Draw #1	9/1/2016	9/20/2016	<5.0 PPB
School District 113	Highland Park High School	A106 teacher café	Water Cooler Draw #2	9/1/2016	9/20/2016	<5.0 PPB
School District 113	Highland Park High School	A106 teacher café	Sink A Draw #1	9/1/2016	9/13/2016	5.0 PPB
School District 113	Highland Park High School	A106 teacher café	Sink A Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A106 teacher café	Sink B Draw #1	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Highland Park High School	A106 teacher café	Sink B Draw #2	9/1/2016	9/13/2016	<5.0 PPB
School District 113	Transportation	Transportation	Water Cooler Draw #1	9/7/2016	9/12/2016	<5.0 PPB
School District 113	Transportation	Transportation	Water Cooler Draw #2	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Transportation	Transportation	Sink A Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Transportation	Transportation	Sink A Draw #2	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Transportation	Concession Stand	Sink B Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Transportation	Concession Stand	Sink B Draw #2	9/7/2016	9/14/2016	<5.0 PPB

**Highland Park
Public Facilities**

Note: "< 5.0 PPB"
indicates that Lead was
NOT DETECTED

Agency	Facility	Location	Tap	Collect Date	Anal Date	Pb Value
School District 113	Wolters Field	Wolters Field Concession Stand	Fountain B Draw #2-Lower	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building	Fountain Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building	Fountain Draw #2	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building	Ice Machine Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building	Ice Machine Draw #2	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Concession Stand	Fountain A Draw #1-Upper	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Concession Stand	Fountain A Draw #2-Upper	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Concession Stand	Fountain B Draw #1-Lower	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Concession Stand	Fountain B Draw #2-Lower	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Concession Stand	Fountain C Draw #1-Upper	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Concession Stand	Fountain C Draw #2-Upper	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Hall	Fountain-Draw #1-Upper	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Hall	Fountain-Draw #2-Upper	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Hall	Fountain-Draw #1-Lower	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Hall	Fountain-Draw #2-Lower	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Girl's Locker Room	Fountain-Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Girl's Locker Room	Fountain-Draw #2	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Boy's Locker Room	Fountain-Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Boy's Locker Room	Fountain-Draw #2	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Visitor's Room	Fountain-Draw #1	9/7/2016	9/14/2016	<5.0 PPB
School District 113	Wolters Field	Wolters Field Athletic Building Visitor's Room	Fountain-Draw #2	9/7/2016	9/2/2016	<5.0 PPB