

PUBLIC NOTICE OF SURFACE WATER TREATMENT TECHNIQUE: [NON-ACUTE]

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. [These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.]

The City of Kemp, PWS ID **TX1290004**, failed to meet the minimum treatment technique requirements for the month of February 2021. Specifically, our water system had more than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Luis Valentin at (903) 603-6306 or luis.valentin@cityofkemp.org

Posted /Delivered on: march 10, 2021
