



# GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038

Phone: (800) 699-9920 | (603) 432-3044

website: www.granitestateanalytical.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 07/29/2020  
CLIENT NAME: American Water Systems  
CLIENT ADDRESS: PO Box 47  
Center Harbor, NH 03226

SAMPLE ID#: 2007-04233-001  
SAMPLED BY: Client-Customer

SAMPLE ADDRESS: N. Sandwich  
NH 03227

### MORE LOC INFO:

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

DATE AND TIME COLLECTED: 07/27/2020 10:15AM  
DATE AND TIME RECEIVED: 07/28/2020 11:45AM  
ANALYSIS PACKAGE: MPN  
RECEIPT TEMPERATURE: ON ICE 6.7° CELSIUS  
CLIENT JOB #

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date-Time Analyzed
Coliform MPN*	29.5	MPN/100mL			1	No Limit	SM 9223B	DG-NH	07/29/20 9:10AM
E. coli MPN*	< 1	MPN/100mL			1	0	SM 9223B	DG-NH	07/29/20 9:10AM
Total Coliform / E.coli Bacteria Preparation							SM 9223B	DG-NH	07/28/20 2:31PM

The results presented in this report relate to the samples listed above in the condition in which they were received.

RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

\* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.  
Laboratory Director

This analysis meets NELAP requirements except as noted.

State Certifications: | NH 1015 | MA M-NH003 | ME NH00003 | RI 101513 | VT VT-101507 |

This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical Services, LLC