



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038

Phone: (800) 699-9920 | (603) 432-3044

website: www.granitestateanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 08/27/2020
CLIENT NAME: American Water Systems
CLIENT ADDRESS: PO Box 47
Center Harbor, NH 03226

SAMPLE ID#: 2008-03849-001
SAMPLED BY: Ole Anderson

SAMPLE ADDRESS: Ole Anderson
113 A Spring
Sandwich NH 03227

MORE LOC INFO:

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

DATE AND TIME COLLECTED: 08/25/2020 3:00PM
DATE AND TIME RECEIVED: 08/26/2020 11:47AM
ANALYSIS PACKAGE: MPN
RECEIPT TEMPERATURE: ON ICE 8.1° CELSIUS
CLIENT JOB #

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date-Time Analyzed
Coliform MPN*	9.1	MPN/100mL			1	No Limit	SM 9223B	DG-NH	08/27/20 9:05AM
E. coli MPN*	< 1	MPN/100mL			1	0	SM 9223B	DG-NH	08/27/20 9:05AM
Total Coliform / E.coli Bacteria Preparation							SM 9223B	DG-NH	08/26/20 1:41PM

The results presented in this report relate to the samples listed above in the condition in which they were received.
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director