

2019 Lead and Copper Sample Results

Sample No.	Sample Date	Copper (µg/L)	Lead (µg/L)
1	7/9/2019	23.8	<1.0
2	7/9/2019	20.8	<1.0
3	7/9/2019	14.1	2.1
4	7/9/2019	12.2	<1.0
5	7/10/2019	17	<1.0
6	7/9/2019	11.6	<1.0
7	7/9/2019	36.7	<1.0
8	7/9/2019	19.8	1.4
9	7/10/2019	39	<1.0
10	7/10/2019	33.9	<1.0
11	7/9/2019	29.6	<1.0
12	7/9/2019	22.1	1.3
13	7/9/2019	10.2	<1.0
14	7/9/2019	10.5	<1.0
15	7/10/2019	32.2	1.2
16	7/9/2019	6.96	<1.0
17	7/9/2019	11.5	<1.0
18	7/9/2019	24.5	<1.0
19	7/9/2019	4.03	<1.0
20	7/9/2019	22	3.1
21	7/12/2019	21.3	<1.0
22	7/9/2019	27.5	<1.0
23	7/9/2019	15.1	<1.0
24	7/9/2019	21.2	<1.0
25	7/22/2019	9.9	<1.0
26	7/9/2019	11.1	<1.0
27	7/9/2019	21.3	<1.0
28	7/9/2019	46	<1.0
29	7/9/2019	15.1	<1.0
30	7/9/2019	31	<1.0
31	7/9/2019	71.8	<1.0
32	7/9/2019	29.7	<1.0
33	7/9/2019	16.0	<1.0
34	7/9/2019	40	2.4
35	7/9/2019	32	<1.0
36	7/9/2019	31.8	<1.0
37	7/9/2019	1.57	<1.0
38	7/9/2019	45.3	<1.0
39	7/9/2019	25.1	<1.0
40	7/10/2019	57.4	<1.0

90th Percentile of Copper Samples' Results: 40 µg/L

EPA action level for copper in drinking water: 1300 µg/L

90th Percentile of Lead Samples' Results: 1.3 µg/L

EPA action level for lead in drinking water: 15 µg/L

Note: µg/L = microgram per liter or parts per billion (ppb)