

2022 Lead and Copper Sample Results

Sample No.	Date	Lead (µg/L)	Copper (µg/L)
1	7/20/2022	2.5	173.0
2	7/15/2022	<1.0	21.7
3	7/14/2022	<1.0	10.5
4	7/14/2022	<1.0	19.0
5	7/14/2022	<1.0	28.8
6	7/14/2022	<1.0	34.6
7	7/14/2022	<1.0	26.8
8	7/13/2022	<1.0	24.3
9	7/14/2022	1.3	217.0
10	7/14/2022	<1.0	7.5
11	7/14/2022	<1.0	12.0
12	7/14/2022	<1.0	34.8
13	7/22/2022	<1.0	20.7
14	7/14/2022	<1.0	17.4
15	7/14/2022	<1.0	30.0
16	7/14/2022	2.2	27.2
18	7/14/2022	<1.0	33.0
20	7/20/2022	<1.0	23.7
21	7/14/2022	1.1	7.6
22	7/14/2022	<1.0	33.7
23	7/14/2022	<1.0	14.5
24	7/14/2022	18	13.5
25	7/14/2022	3.2	49.1
26	7/11/2022	<1.0	6.7
27	7/14/2022	5.8	34.9
29	7/14/2022	<1.0	12.6
30	7/14/2022	<1.0	109.0
37	7/15/2022	<1.0	19.5
39	7/14/2022	<1.0	5.7
41	7/22/2022	<1.0	1.5

90th Percentile of Lead Samples' Results: 2.5 µg/L

EPA action level for lead in drinking water: 15 µg/L

90th Percentile of Copper Samples' Results: 49.1 µg/L

EPA action level for lead in drinking water: 1300 µg/L

Note: µg/L = microgram per liter or parts per billion (ppb)