



CASCADE
--- TOWNSHIP ---

2025 75TH ST. NE
Rochester, MN 55906
www.cascadetownship.us

April 17, 2014


Town Board Inspection Meeting Minutes

Supervisors Heathman and Laures of the Cascade Town Board met at the River Highlands development for the purpose of inspecting an active construction site by Pahl & Kaye builders. The following issues were noted:


- Two (2) driveways have been installed in violation of the Cascade Township Access ordinance.
- No erosion control was in place. No silt fencing had been installed.
- The culvert used for the one driveway had not been approved and was too short.
- Spring road restrictions are in place and the deliveries of concrete, foundation framing, and backfill rock are all overweight.
- The roadway adjacent to the driveways has broken due to the truck traffic.

The builder was made aware that only one driveway is permitted and silt fencing is required. The builder will repair the roadway when the driveway is paved. The builder and drivers were required to take action to reduce truck weights to a permissible level.

Submitted: Michael Brown, Clerk/Treasurer



Michael Brown, Clerk/Treasurer



Lenny Laures, Chairman

