



## CITY OF COLLEGE PLACE

---

Public Works Department  
625 South College Avenue  
College Place, WA 99324  
509-394-8526

11-1-2019

Comments on Whispering Meadows

Street Name – to be submitted to City for approval

Water main shall be 8" DI fully restrained

FH at 8<sup>th</sup> and entrance to street and at end of cul-de-sac

Water & Sewer to all lots

Sewer main shall be 8"

Manholes would be at tie-in on 8th at end of main in cul-de-sac

Street name sign and stop sign following City standard and installed on 3#/ft u-channel post at intersection with new street

5' additional frontage along SE 8<sup>th</sup> for a total 1/2 ROW of 25'

Curb & sidewalk along 8<sup>th</sup> street frontage and new street

1/2 street improvements on SE 8<sup>th</sup> to City standards with overlay over remaining chip seal

I certify that the proposed street, sewage disposal and water supply systems, as proposed and developed to city standards and specifications, will be adequate to serve the needs of the proposed subdivision and recommend approval.

Paul Hartwig  
Public Works Director  
City of College Place