



## CITY OF COLLEGE PLACE

---

Public Works Department  
625 South College Avenue  
College Place, WA 99324  
509-394-8526

January 17, 2019

Thad Sirmon  
54 W Rees Avenue  
Walla Walla, WA 99362

Dear Mr. Sirmon:

I am writing to outline the City of College Place's requirements for fire flow testing for your Spitzenburg Apartment Complex project.

You will be required to obtain a certified fire flow test. The test can be conducted by an approved certified fire protection engineer or an approved certified fire sprinkler contractor.

You will need to obtain permission from Green Tank Water District 11 prior to testing. The test will be conducted in accordance with NFPA 291. Testing will need to be observed by the College Place Fire Marshal. Test results and certification documents will need to be provided to the College Place Fire Marshal.

Your required fire flow will be 1000 GPM for 2 hours if you install a NFPA 13 sprinkler system which provides for life safety and protects the entire building. Your required fire flow will be 1500 GPM for 2 hours if you install a NFPA 13R sprinkler system which is primarily designed for life safety only. At no time can the system pressure drop below 20psi.

If you have any questions, please feel free to contact me.

Respectfully,

John Boose  
Fire Marshal  
College Place Fire Department

Paul Hartwig  
Public Works Director  
City of College Place