


RECEIVED

By cholm at 8:00 am, Aug 01, 2019



VAN VOORHIES, PE
46 MEADOWLARK LANE
TOUCHET, WASHINGTON 99362
van@appellationeng.com

509-200-6538 CELL
Project 19-24
July 31, 2019

City of College Place Community Development
Mr. Jon Rickard
625 South College Avenue
College Place, WA. 99324

An infiltration test pip was dug on site to a depth of 5' deep. No water was encountered but dirty gravels were found in the bottom of the pit. The most recent well drilled in the area has a standing water level of 12 feet. Gravels were encountered from 5 feet to 25 feet concurring with our findings. The basement of the home at 620 S.E. is approximately 7 feet deep and has not had water in the basement at any season. I was able to ask this question to the previous long term resident. Garrison Creek surface elevations are about 5 feet below the nearest building sites. This is compatible with the above findings.

Due to these findings I concur that the water table in the gravels and the site in not subject to liquefaction.

Best Regards,

A handwritten signature in blue ink, appearing to read "Ray Van Voorhies, Jr.", written in a cursive style.

Van Voorhies, PE

