



## ISLAMORADA, VILLAGE OF ISLANDS, FLORIDA

### ADDENDUM NO. 1

## FOUNDERS PARK TENNIS COURTS RESURFACING PROJECT (RFP 23-06)

*ISSUE DATE: March 15, 2023*

**This Addendum forms a part of the Request for Proposals (RFP) and clarifies the original RFP.**

**Question 1:** We respectfully submit for your consideration a request to approve products as an accepted substitute on SMS: Founders Park Tennis Courts Resurfacing Project.

The specific product substitutions requested for approval were Plexipave, DecoColor manufactured by ICP Building Solutions.

**Answer:** The Village would accept the proposed substitutions. With any product substitution, proposers are asked to provide clarification that fiberglass mesh would be installed over all existing cracks, as required by Section VIII. 1.0 2. of the RFP. The installation of fiberglass mesh is the preferred restoration method to be utilized.