

STATE OF SOUTH CAROLINA  
COUNTY OF SPARTANBURG  
TOWN OF LYMAN

**ORDINANCE NO. 09142020** G

**AN ORDINANCE AMENDING TOWN OF LYMAN, SOUTH CAROLINA, LAND  
DEVELOPMENT REGULATIONS:  
SECTION 6.18: FIRE HYDRANTS**


**WHEREAS**, the Town Council has determined that it is in the interest of the Town, for the benefit of the health, order, safety, general welfare and convenience of the Town and its residents, to amend the Town of Lyman, South Carolina, Land Development Regulations, to amend Section 6.18: Fire Hydrants.


**NOW, THEREFORE, BE IT ORDAINED BY THE MAYOR AND COUNCILMEMBERS OF THE TOWN OF LYMAN IN COUNCIL ASSEMBLED**, that the current Section 6.18: Fire Hydrants is hereby amended to add the requirement for all fire hydrants to have the Storz adapter (5" Storz x 4.5" NH fire hydrant converter). The revised Section 6.18 Fire Hydrants shall read as follows:

**Section 6.18: Fire Hydrants**

"Fire hydrants shall be installed and spaced throughout each subdivision to maintain a one thousand (1,000) foot road distance between hydrants. All fire hydrants must have the Storz adapter (5" Storz x 4.5 NH fire hydrant converter). The Fire Service provider covering the Town of Lyman shall approve the location and spacing of the hydrants."

This Ordinance shall take effect upon second reading approval by the Town Council.

ATTEST:   
**R. Noel Price Blackwell, Town Clerk**

  
**Larry Chappell, Mayor**

First Reading: 9/14/2020 Second Reading: 10/12/2020

## PROPOSED AMENDMENT TO THE LAND DEVELOPMENT REGULATIONS

Attached please find:

1. Current Land Development Regulations Sec. 6.18: FIRE HYDRANTS. Fire hydrants shall be installed and spaced throughout each subdivision to maintain a on thousand (1,000) foot road distance between hydrants. The Fire Service Provider covering the Town of Lyman shall approve the location and spacing of the hydrants, item proposed to be revised highlighted.

2. Proposed revised Land Development Regulations Sec. 6.18, item proposed to be revised highlighted.

### DESCRIPTION OF ITEMS PROPOSED FOR AMENDMENT:

- Original adopted version  
Sec. 6.18: FIRE HYDRANTS. Fire hydrants shall be installed and spaced throughout each subdivision to maintain a on thousand (1,000) foot road distance between hydrants. The Fire Service Provider covering the Town of Lyman shall approve the location and spacing of the hydrants, item proposed to be revised highlighted.

The proposed amendment is to add a new requirement for all fire hydrants "all fire hydrants must have the storz adapter (5" stroz X 4.5" NH fire hydrant converter).

## **ORIGINAL ADOPTED ORDINANCE**

### **SECTION 6.18: FIRE HYDRANTS**

Fire hydrants shall be installed and spaced throughout each subdivision to maintain a one thousand (1,000) foot road distance between hydrants. The Fire Service Provider covering the Town of Lyman shall approve the location and spacing of the hydrants.

## PROPOSED ORDINANCE

### SECTION 6.18: FIRE HYDRANTS

Fire hydrants shall be installed and spaced throughout each subdivision to maintain a one thousand (1,000) foot road distance between hydrants. All Fire hydrants must have the storz adapter (5" stroz x 4.5" NH fire hydrant converter). The Fire Service Provider covering the Town of Lyman shall approve the location and spacing of the hydrants.

