



2021
ACTIVITY FOR SAN JUAN BAUTISTA

FEBRUARY

FIRES	2
EMERGENCY MEDICAL SERVICES	17
VEHICLE ACCIDENTS	6

INSPECTIONS	5
-------------	---

(RESIDENTIAL, COMMERCIAL, SCHOOLS, APARTMENTS, HOTEL/MOTELS)

NOTES:

HARVEY'S LOCK UP property has a fully monitored smoke and heat detectors in the entire facility. The first and second part of the building has a fully monitored sprinkler system. The last phase of the building where the resident's are is next to install last phase of the sprinkler system. There are monitored smoke detectors in each unit. The alarm system was above and beyond requirements until it is fully sprinklered. There have been detectors that have been removed now because they are causing false alarms from rain leaks damaging the detectors. They were only removed on sprinklered sections. Not needed after sprinklers are installed.

E14 and W52 responded to a vehicle fire. While in route dispatch informed us that the building's fire alarm next to the vehicle was sounding. The building next to the car was not being impinged on but the smoke was drifting directly on to Harvey's Lock Up. It was Harvey Lock up alarm system that also notified the fire department of the fire. The vehicle fire was extinguished and firefighters checked the building for fire extension. There was no spread of fire and the fire alarm was reset.

