



State Water Resources Control Board


Division of Drinking Water

Lead and Copper Tap Sample Results Reporting Form

This form must be submitted by the public water system to the regulating entity (DDW District Office or County Agency) for each round of lead and copper sampling

Report Date: (mm/dd/yyyy)	11-10-2018
Water System Name:	City of San Juan Bautista
Water System Number:	3510002
Water System Type:	☒ Community ☐ Non-Transient, Non Community
Monitoring Frequency:	☐ 6-month ☐ Annual ☒ Triennial
# of Samples Required:	10
# of Samples Reported:	10
90th Percentile Level (mg/L)	
Lead: <i>Action Level = 0.015 mg/L</i>	0.066
Copper: <i>Action Level = 1.3 mg/L</i>	0.111

				Result	
	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Lead (mg/L)	Copper (mg/L)
01	9/18/2018	10 Jefferson St		0.0066	0.097
02	9/18/2018	167 Lang St		0.0071	0.127
03	9/15/2018	54 Muckelemini		0.0026	0.038
04	9/16/2018	68 Polk St		ND	0.034
05	9/16/2018	202 7 th St		0.0014	0.068
06	9/16/2018	51 Franklin St		0.0030	0.111
07	9/16/2018	41 Monterey St		0.0011	0.051
08	9/16/2018	15 North St		ND	0.024
09	9/16/2018	509 6 th St		0.0018	0.235
10	9/16/2018	38 Church St		ND	0.028
11					
12		To the best of my knowledge there are no sites within the Distribution system that meet the criteria for tier 1,2 or 3			
13					
14					
15					
16					
17					
18					
19					
20					



MBAS

Monterey Bay Analytical Services

City of San Juan Bautista
Daniel Gonzales
311 2nd St.
San Juan Bautista, CA 95045

4 Justin Court Suite D, Monterey, CA 93940
831.375.MBAS (6227)
www.MBASinc.com

ELAP Certification Number: 2385

Thursday, September 27, 2018

Lab Number 180924_35-01 Sample Description: City of San Juan Bautista, 10 Jefferson St

Collection Date/Time: 9/18/2018 7:30 Sample Collector: Gonzales, D Client Sample #:
Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002

Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.10	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	97.5	1		2		9/26/2018	13:03	MW
Lead, Total	EPA200.8	µg/L	6.6	1		1	15	9/26/2018	13:03	MW

Lab Number 180924_35-02 Sample Description: City of San Juan Bautista, 167 Lang St

Collection Date/Time: 9/18/2018 7:12 Sample Collector: Gonzales, D Client Sample #:
Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002

Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.21	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	127.0	1		2		9/26/2018	13:05	MW
Lead, Total	EPA200.8	µg/L	7.1	1		1	15	9/26/2018	13:05	MW

Lab Number 180924_35-03 Sample Description: City of San Juan Bautista, 54 Muckelemi

Collection Date/Time: 9/15/2018 9:00 Sample Collector: Gonzales, D Client Sample #:
Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002

Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.07	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	38.1	1		2		9/26/2018	13:07	MW
Lead, Total	EPA200.8	µg/L	2.6	1		1	15	9/26/2018	13:07	MW

Lab Number 180924_35-04 Sample Description: City of San Juan Bautista, 68 Polk St

Collection Date/Time: 9/16/2018 4:08 Sample Collector: Gonzales, D Client Sample #:
Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002


Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.13	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	34.9	1		2		9/26/2018	13:09	MW
Lead, Total	EPA200.8	µg/L	ND	1		1	15	9/26/2018	13:09	MW

mg/L : Milligrams per liter (=ppm)
H = Analyzed outside of hold time
MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)
E = Analysis performed by External Laboratory; See Report attachments
J = Result is less than PQL

PQL : Practical Quantitation Limit

MCL : Maximum Contamination Level
T = Temperature Exceedance



MBAS

Monterey Bay Analytical Services

City of San Juan Bautista
 Daniel Gonzales
 311 2nd St.
 San Juan Bautista, CA 95045

4 Justin Court Suite D, Monterey, CA 93940
 831.375.MBAS (6227)
 www.MBASinc.com

ELAP Certification Number: 2385

Thursday, September 27, 2018

Lab Number 180924_35-05 Sample Description: City of San Juan Bautista, 202 7th St

Collection Date/Time: 9/16/2018 8:00 Sample Collector: Gonzales, D Client Sample #:
 Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002

Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.13	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	68.6	1		2		9/26/2018	13:11	MW
Lead, Total	EPA200.8	µg/L	1.4	1		1	15	9/26/2018	13:11	MW

Lab Number 180924_35-06 Sample Description: City of San Juan Bautista, 51 Franklin St

Collection Date/Time: 9/16/2018 8:30 Sample Collector: Gonzales, D Client Sample #:
 Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002

Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.07	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	111.0	1		2		9/26/2018	13:13	MW
Lead, Total	EPA200.8	µg/L	3.0	1		1	15	9/26/2018	13:13	MW

Lab Number 180924_35-07 Sample Description: City of San Juan Bautista, 41 Monterey St

Collection Date/Time: 9/16/2018 7:50 Sample Collector: Gonzales, D Client Sample #:
 Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002

Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.21	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	51.9	1		2		9/26/2018	13:40	MW
Lead, Total	EPA200.8	µg/L	1.1	1		1	15	9/26/2018	13:40	MW

Lab Number 180924_35-08 Sample Description: City of San Juan Bautista, 15 North St

Collection Date/Time: 9/16/2018 7:00 Sample Collector: Gonzales, D Client Sample #:
 Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002

Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.09	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	24.5	1		2		9/26/2018	13:42	MW
Lead, Total	EPA200.8	µg/L	ND	1		1	15	9/26/2018	13:42	MW

mg/L : Milligrams per liter (=ppm)

H = Analyzed outside of hold time

MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)


E = Analysis performed by External Laboratory; See Report attachments

J = Result is less than PQL

PQL : Practical Quantitation Limit

MCL : Maximum Contamination Level

T = Temperature Exceedance



MBAS

Monterey Bay Analytical Services

City of San Juan Bautista
Daniel Gonzales
311 2nd St.
San Juan Bautista, CA 95045

4 Justin Court Suite D, Monterey, CA 93940
831.375.MBAS (6227)
www.MBASinc.com

ELAP Certification Number: 2385

Thursday, September 27, 2018

Lab Number 180924_35-09 Sample Description: City of San Juan Bautista, 509 6th St

Collection Date/Time: 9/16/2018 7:00 Sample Collector: Gonzales, D Client Sample #:
Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002


Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.14	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	23.5	1		2		9/26/2018	13:44	MW
Lead, Total	EPA200.8	µg/L	1.8	1		1	15	9/26/2018	13:44	MW

Lab Number 180924_35-10 Sample Description: City of San Juan Bautista, 38 Church St

Collection Date/Time: 9/16/2018 4:30 Sample Collector: Gonzales, D Client Sample #:
Submittal Date/Time: 9/24/2018 15:20 Sample ID: 3510002

Analyte	Method	Unit	Result	Dil.	Qual	PQL	MCL	Anal. Date	Anal. Time	Analyst
Turbidity Screen Pb/Cu Rule	EPA180.1	NTU	0.15	1		0.05		9/25/2018	11:18	MW
Copper, Total	EPA200.8	µg/L	28.0	1		2		9/26/2018	13:46	MW
Lead, Total	EPA200.8	µg/L	ND	1		1	15	9/26/2018	13:46	MW

Report Approved by:


David Holland, Laboratory Director

mg/L : Milligrams per liter (=ppm)

H = Analyzed outside of hold time

MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)

E = Analysis performed by External Laboratory; See Report attachments

J = Result is less than PQL

PQL : Practical Quantitation Limit

MCL : Maximum Contamination Level

T = Temperature Exceedance