



MONTEREY COUNTY HEALTH DEPARTMENT

Consolidated Chemistry Laboratory

1270 Natividad Road Salinas, CA 93906
Phone (831)755-4516 Fax (831) 755-4652

ELAP Certification Number: 1395

City of San Juan Bautista
311 Second Street
San Juan Bautista, CA 95045

Lab Number: AC18251 Client Code: SJBAUTISTA
Sample Site: CITY MAINTENANCE YARD Collection Date/Time: 11/20/2018 17:58
Source Code: Submittal Date/Time: 11/21/2018 10:18
Other ID: 3510002 Sample Collector: GONZALES D

Sample Comments: Repeat Drinking Water. Copy sent to WB-DDW. Chlorine residual 0.30. Receiving temperature 5.8°C.

Table with 8 columns: Analyte, Method, Unit, Result, DLR, MCL, PQL, Analysis Start Date/Time. Rows for Coliforms; E. coli and Coliforms; total.

Lab Number: AC18252 Client Code: SJBAUTISTA
Sample Site: 27 JEFFERSON ST Collection Date/Time: 11/20/2018 18:32
Source Code: Submittal Date/Time: 11/21/2018 10:18
Other ID: 3510002 Sample Collector: GONZALES D

Sample Comments: Repeat Drinking Water. Copy sent to WB-DDW. Chlorine residual 0.25. Receiving temperature 6.4°C.

Table with 8 columns: Analyte, Method, Unit, Result, DLR, MCL, PQL, Analysis Start Date/Time. Rows for Coliforms; E. coli and Coliforms; total.

Lab Number: AC18253 Client Code: SJBAUTISTA
Sample Site: 602 2ND ST Collection Date/Time: 11/20/2018 18:23
Source Code: Submittal Date/Time: 11/21/2018 10:18
Other ID: 3510002 Sample Collector: GONZALES D

Sample Comments: Repeat Drinking Water. Copy sent to WB-DDW. Chlorine residual 0.20. Receiving temperature 5.7°C.

Table with 8 columns: Analyte, Method, Unit, Result, DLR, MCL, PQL, Analysis Start Date/Time. Rows for Coliforms; E. coli and Coliforms; total.

mg/L : Milligrams per liter (=ppm) ug/L : Micrograms per liter (=ppb) * : Primary Standards
PQL : Practical Quantitation Limit MCL : Maximum Contaminant Level ** : Secondary Standards
DLR : Detection Limit for Reporting ND : Not Detected N/A : Not Applicable *** : Action Level

Lab Number: AC18254

Sample Site: WELL 005

Source Code:

Other ID: 3510002

Client Code: SJBAUTISTA

Collection Date/Time: 11/20/2018 19:00

Submittal Date/Time: 11/21/2018 10:18

Sample Collector: GONZALES D

Sample Comments: Repeat Drinking Water. Copy sent to WB-DDW. Chlorine residual 0.0. Receiving temperature 5.5°C.

Analyte	Method	Unit	Result	DLR	MCL	PQL	Analysis Start Date/Time
Coliforms; E. coli	SM9223	#/100 mL	ABSENT	N/A	1/10	1	11/21/2018 14:55
Coliforms; total	SM9223	#/100 mL	ABSENT	N/A	1/10	1	11/21/2018 14:55

Report approved by:



Donna Ferguson, Ph.D, P.H.M
Laboratory Director

mg/L : Milligrams per liter (=ppm)

PQL : Practical Quantitation Limit

DLR : Detection Limit for Reporting

ug/L : Micrograms per liter (=ppb)

MCL : Maximum Contaminant Level

ND : Not Detected

* : Primary Standards

** : Secondary Standards

N/A : Not Applicable

*** : Action Level