



MBAS

Monterey Bay Analytical Services

4 Justin Court Suite D, Monterey, CA 93940

831.375.MBAS (6227)

www.MBASinc.com

ELAP Certification Number: 2385

City of San Juan Bautista

Daniel Gonzales

311 2nd St.

San Juan Bautista, CA 95045

Friday, September 28, 2018

Lab Number: 180924_39-01

Collection Date/Time: 9/24/2018 8:50

Sample Collector:

Madrigal, J Client Sample #:

Submittal Date/Time: 9/24/2018 15:19

Sample ID:


3510002 Coliform Designation:

Sample Description: City of San Juan Bautista, City Maintenance Yard

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1		9/24/2018	16:10	MW
Coliform, Total	Colitag-24hr	MPN/100mL	Absent		1		9/24/2018	16:10	MW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	0.88		1		9/24/2018	8:50	

Comments:

Report Approved by:


David Holland, Laboratory Director

mg/L : Milligrams per liter (=ppm)

H = Analyzed outside of hold time

MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)

E = Analysis performed by External Laboratory; See Report attachments

J = Result is less than PQL

PQL : Practical Quantitation Limit

Page 1 of 3

MCL : Maximum Contamination Level

T = Temperature Exceedance



MBAS

Monterey Bay Analytical Services

4 Justin Court Suite D, Monterey, CA 93940

831.375.MBAS (6227)

www.MBASinc.com

ELAP Certification Number: 2385

City of San Juan Bautista

Daniel Gonzales

311 2nd St.

San Juan Bautista, CA 95045

Friday, September 28, 2018

Sample Condition Upon Receipt

Sample at recommended temperature (Chemistry < or =6°C, Micro < or =10°C?), or within 2 hrs?	Yes
Did bottle arrive intact?	Yes
Did bottle labels agree with COC?	Yes
Adequate sample volume?	Yes
Is there evidence of chilling?	Yes

mg/L : Milligrams per liter (=ppm)

H = Analyzed outside of hold time

MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)

E = Analysis performed by External Laboratory; See Report attachments

J = Result is less than PQL

PQL : Practical Quantitation Limit

Page 2 of 3

MCL : Maximum Contamination Level

T = Temperature Exceedance

