



# MBAS

## Monterey Bay Analytical Services

4 Justin Court Suite D, Monterey, CA 93940

831.375.MBAS (6227)

www.MBASinc.com

ELAP Certification Number: 2385

### City of San Juan Bautista

Daniel Gonzales

311 2nd St.

San Juan Bautista, CA 95045

Tuesday, October 16, 2018

#### Lab Number: 181015\_35-01

Collection Date/Time: 10/15/2018 12:49

Sample Collector:

Madrigal, J Client Sample #:

Submittal Date/Time: 10/15/2018 15:14

Sample ID:


3510002 Coliform Designation:

#### Sample Description: City of San Juan Bautista, 68 Polk St

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1		10/15/2018	15:40	MW
Coliform, Total	Colitag-24hr	MPN/100mL	Absent		1		10/15/2018	15:40	MW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	1.30		1		10/15/2018	12:49	

#### Comments:

Report Approved by:

  
David Holland, Laboratory Director

mg/L : Milligrams per liter (=ppm)

H = Analyzed outside of hold time

MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)

E = Analysis performed by External Laboratory; See Report attachments

J = Result is less than PQL

PQL : Practical Quantitation Limit

MCL : Maximum Contamination Level

T = Temperature Exceedance



# MBAS

## Monterey Bay Analytical Services

4 Justin Court Suite D, Monterey, CA 93940

831.375.MBAS (6227)

[www.MBASinc.com](http://www.MBASinc.com)

ELAP Certification Number: 2385

**City of San Juan Bautista**

Daniel Gonzales

311 2nd St.

San Juan Bautista, CA 95045

Tuesday, October 16, 2018

### Sample Condition Upon Receipt

**Order ID: 181015\_35**

Is there evidence of chilling?

Yes

\*NOTE: Systems are encouraged but not required to hold samples  
<10°C (Microbiology) or <6°C (Chemistry) during transit.

Did bottle arrive intact?

Yes

Did bottle labels agree with COC?

Yes

Adequate sample volume?

Yes

