

City of San Juan Bautista
 DDW
 311 2nd St.
 San Juan Bautista, CA 95045

4 Justin Court Suite D, Monterey, CA 93940
 831.375.MBAS (6227)
 www.MBASinc.com

ELAP Certification Number: 2385
 Monday, January 14, 2019

Lab Number: 190108_34-01

Collection Date/Time: 1/8/2019 8:52 Sample Collector: Madrigal, J Client Sample #:
 Submittal Date/Time: 1/8/2019 12:27 Sample ID: 3510002 Coliform Designation: Routine

Sample Description: City of San Juan Bautista, 68 Polk St

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1	1	1/8/2019	17:10	MW
Coliform, Total	Colitag-24hr	MPN/100mL	Absent		1	1	1/8/2019	17:10	MW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	0.85		1	0.05	1/8/2019	8:52	

Comments:

Lab Number: 190108_34-02

Collection Date/Time: 1/8/2019 10:53 Sample Collector: Madrigal, J Client Sample #:
 Submittal Date/Time: 1/8/2019 12:27 Sample ID: 3510002-010 Coliform Designation: Other

Sample Description: City of San Juan Bautista, Well-006

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1	1	1/8/2019	17:10	MW
Coliform, Total	Colitag-24hr	MPN/100mL	Present		1	1	1/8/2019	17:10	MW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	0.00		1	0.05	1/8/2019	10:53	

Comments:

Lab Number: 190108_34-03

Collection Date/Time: 1/8/2019 11:39 Sample Collector: Madrigal, J Client Sample #:
 Submittal Date/Time: 1/8/2019 12:27 Sample ID: 3510002-001 Coliform Designation: Other

Sample Description: City of San Juan Bautista, Well-001

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1	1	1/8/2019	17:10	MW
Coliform, Total	Colitag-24hr	MPN/100mL	Absent		1	1	1/8/2019	17:10	MW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	0.00		1	0.05	1/8/2019	11:39	

Comments:



MBAS

Monterey Bay Analytical Services

4 Justin Court Suite D, Monterey, CA 93940

831.375.MBAS (6227)

www.MBASinc.com

ELAP Certification Number: 2385

Monday, January 14, 2019

City of San Juan Bautista

DDW

311 2nd St.

San Juan Bautista, CA 95045

Lab Number: 190108_34-04

Collection Date/Time: 1/8/2019 11:50

Sample Collector:

Madrigal, J Client Sample #:

Submittal Date/Time: 1/8/2019 12:27

Sample ID:


3510002-009 Coliform Designation: Other

Sample Description: City of San Juan Bautista, Well-005

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1	1	1/8/2019	17:10	MW
Coliform, Total	Colitag-24hr	MPN/100mL	Absent		1	1	1/8/2019	17:10	MW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	0.00		1	0.05	1/8/2019	11:50	

Comments:

Report Approved by:


David Holland, Laboratory Director

mg/L : Milligrams per liter (=ppm)

H = Analyzed outside of hold time

MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)

E = Analysis performed by External Laboratory; See Report attachments

J = Result is less than PQL

PQL : Practical Quantitation Limit

MCL : Maximum Contamination Level

T = Temperature Exceedance



MBAS

Monterey Bay Analytical Services

4 Justin Court Suite D, Monterey, CA 93940

831.375.MBAS (6227)

www.MBASinc.com

ELAP Certification Number: 2385

Monday, January 14, 2019

City of San Juan Bautista

DDW

311 2nd St.

San Juan Bautista, CA 95045

Sample Condition Upon Receipt

Order ID: 190108_34

Is there evidence of chilling?

Yes

*NOTE: Systems are encouraged but not required to hold samples
<10°C (Microbiology) or <6°C (Chemistry) during transit.

Did bottle arrive intact?

Yes

Did bottle labels agree with COC?

Yes

Adequate sample volume?

Yes

mg/L : Milligrams per liter (=ppm)

H = Analyzed outside of hold time

MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)

E = Analysis performed by External Laboratory; See Report attachments

J = Result is less than PQL

PQL : Practical Quantitation Limit

MCL : Maximum Contamination Level

T = Temperature Exceedance

