



MBAS

Monterey Bay Analytical Services

4 Justin Court Suite D, Monterey, CA 93940

831.375.MBAS (6227)

www.MBASinc.com

ELAP Certification Number: 2385

Sunday, January 13, 2019

City of San Juan Bautista

DDW

311 2nd St.

San Juan Bautista, CA 95045

Lab Number: 190112_03-01

Collection Date/Time: 1/12/2019 10:25

Sample Collector:

Gonzales, D Client Sample #:

Submittal Date/Time: 1/12/2019 12:00

Sample ID:

3510002-010 Coliform Designation: Special

Sample Description: City of San Juan Bautista, Well-006, 1st

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Chlorine Residual (Field)	SM4500-Cl G	mg/L	0.00		1	0.05	1/12/2019	10:25	
Coliform, E Coli (Quantitray)	SM9223	MPN/100mL	<1		1	1	1/12/2019	14:00	DH
Coliform, Total (Quantitray)	SM9223	MPN/100mL	<1		1	1	1/12/2019	14:00	DH

Comments:

Lab Number: 190112_03-02

Collection Date/Time: 1/12/2019 10:55

Sample Collector:

Gonzales, D Client Sample #:

Submittal Date/Time: 1/12/2019 12:00

Sample ID:


3510002-010 Coliform Designation: Special

Sample Description: City of San Juan Bautista, Well-006, 2nd

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Chlorine Residual (Field)	SM4500-Cl G	mg/L	0.00		1	0.05	1/12/2019	10:25	
Coliform, E Coli (Quantitray)	SM9223	MPN/100mL	<1		1	1	1/12/2019	14:00	DH
Coliform, Total (Quantitray)	SM9223	MPN/100mL	<1		1	1	1/12/2019	14:00	DH

Comments:

Report Approved by:


David Holland, Laboratory Director

mg/L : Milligrams per liter (=ppm)

H = Analyzed outside of hold time

MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)

E = Analysis performed by External Laboratory; See Report attachments

J = Result is less than PQL

PQL : Practical Quantitation Limit

Page 1 of 3

MCL : Maximum Contamination Level

T = Temperature Exceedance

City of San Juan Bautista
DDW
311 2nd St.
San Juan Bautista, CA 95045

4 Justin Court Suite D, Monterey, CA 93940
831.375.MBAS (6227)
www.MBASinc.com

ELAP Certification Number: 2385
Sunday, January 13, 2019

Sample Condition Upon Receipt

Order ID: 190112_03

Is there evidence of chilling? Yes

*NOTE: Systems are encouraged but not required to hold samples
<10°C (Microbiology) or <6°C (Chemistry) during transit.

Did bottle arrive intact?	Yes
Did bottle labels agree with COC?	Yes
Adequate sample volume?	Yes
Additional Comments	< 2 hrs

