



MBAS

Monterey Bay Analytical Services

4 Justin Court Suite D, Monterey, CA 93940

831.375.MBAS (6227)

www.MBASinc.com

ELAP Certification Number: 2385

Wednesday, February 27, 2019

City of San Juan Bautista

DDW

311 2nd St.

San Juan Bautista, CA 95045

Lab Number: 190225_27-01

Collection Date/Time: 2/25/2019 7:46

Sample Collector:

Madrigal, J Client Sample #:

Submittal Date/Time: 2/25/2019 15:27

Sample ID:


3510002 Coliform Designation: Routine

Sample Description: City of San Juan Bautista, City Maintenance Yard

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1	1	2/25/2019	16:15	MW
Coliform, Total	Colitag-24hr	MPN/100mL	Absent		1	1	2/25/2019	16:15	MW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	1.30		1	0.05	2/25/2019	7:46	

Comments:

Report Approved by:


David Holland, Laboratory Director

mg/L : Milligrams per liter (=ppm)

H = Analyzed outside of hold time

MDL = Method Detection Limit

µg/L : Micrograms per liter (=ppb)

E = Analysis performed by External Laboratory; See Report attachments

J = Result is less than PQL

PQL : Practical Quantitation Limit

MCL : Maximum Contamination Level

T = Temperature Exceedance

City of San Juan Bautista
DDW
311 2nd St.
San Juan Bautista, CA 95045

4 Justin Court Suite D, Monterey, CA 93940
831.375.MBAS (6227)
www.MBASinc.com

ELAP Certification Number: 2385
Wednesday, February 27, 2019

Sample Condition Upon Receipt

Order ID: 190225_27

Is there evidence of chilling? Yes


*NOTE: Systems are encouraged but not required to hold samples
<10°C (Microbiology) or <6°C (Chemistry) during transit.

Did bottle arrive intact?	Yes
Did bottle labels agree with COC?	Yes
Adequate sample volume?	Yes

190225-27

Monterey Bay Analytical Services Chain Of Custody / Analysis Request

4 Justin Ct. Suite D • Monterey, Ca 93940 • (831) 375-MBAS (6227) • (831) 641-0734 (Fax)



MBAS

Monterey Bay Analytical Services

Client/Company Name:

City of San Juan Bau

Attention:

DDW

Billing Address:

PO Box 1420 San Juan Bautista Ca 95045

Analysis Requested

Project/System Information:

E-Mail Address(es):

allclearwaterservices@yahoo.com

Contract/P.O. #:

For Regulatory Compliance?

YES

☒

NO

☐

For State or Local Health Department reporting:

Electronic Data Transfer (EDT)?

YES

☐

NO

☐

System ID Number:

3510002

Turn Around Time:

STD (7-14 Days)

☐

48-Hour

☐

5-Day

☐

24-Hour

☒

Phone #

831-537-5057

Fax #

Drinking water

☒

Wastewater

☐

Monitoring Well

☐

Soil

☐

Sludge

☐

Other

☐

MBAS Lab #	Project ID or Source Code #	Sample Site / Description (Well Name, APN#, Address, Stormdrain #)	Sampling Date	Time	Receiving Temp.	CL2 Residual	Coliform Analysis Routine	Other	Repeat	Special	# Cont.	Container Type	Size					
-01		City Maintenance Parcel	2/25/14	7:46	9.3	1.3	X							V				

	Printed Name	Signature	Date	Time	Comments or Special Instructions:
Sampled by:	Jose Madrigal		2/25/14	7:46	
Relinquished by:	Jose Madrigal		2/25/14	8:32	
Received by:	Dylan Jones		2/25/14	1340	
Relinquished by:	Dylan Jones		2/25/14	1527	
Received by:	Pauline Seto Monterey Bay Analytical Services		2/25/14	1527	

☐ Payment received

Check #

Amount:

Receipt #

Date: