

CITY OF HOLLISTER TREATMENT PLANT LABORATORY
Operated by Bracewell Engineering, Inc.
2690 San Juan Hollister Road
Hollister, CA 95023
(831) 636-4350 ext 8

Mr. Ed Tewes
Interim City Manager
City of San Juan Bautista
P.O. Box 1420
San Juan Bautista, CA 95045

ELAP Certification Number: 1520
Report Date: 03/06/18

Name: San Juan Bautista Water System (W3510002)

Location of Sample: Reservoir Sample Type: Grab
Collection Date/time: 02/28/18 @ 7:28 Sampled By: Andres Gomez
Submittal Date/time: 02/28/18 @ 10:00 Sample ID: SJW.1802.RV_.012

Analyte	Method	Units	Result	PQL	QCR %	Analyzed
Nitrate-N	SM4500-NO3 D	mg/L-N	5.2120	0.40	100	02/28/18

PQL = practical quantification limit
QCR % = quality control recovery percent

Report Approved By:



Lloyd Bracewell, PhD
Laboratory Director
lloyd@bracewellengineering.com
(510) 435-7521