

## ACCESSIBILITY

### RAMPS

SLOPE:	The maximum slope for a ramp is <b>1-inch in 12-inches</b> .
RISE:	The maximum rise for a ramp is <b>30-inches</b> .
WIDTH:	Minimum width of <b>36-inches</b> . If on required egress path must be <b>44-inches</b>
LANDINGS:	Bottom of ramp must be <b>72-inches</b> . Mid level & top of ramp minimum <b>60-inches</b> .
DIRECTION CHANGE:	Landings at changes of direction must be <b>60-inch x 60-inch</b> minimum.

### HANDRAILS

REQUIRED:	Handrails are required on both sides of ramps over 6-inches high.
SPACE:	Minimum <b>1 ½"</b> clear space between handrail and wall.
HEIGHT:	Between <b>34-inches</b> and <b>38-inches</b> above ramp surface.
CURBS	Ramps without walls must have <b>curbs or rails</b> up to <b>2-inches</b> above surface.

### DOORS

WIDTH:	Minimum clear opening of <b>32-inches</b> (36-inch door).
THRESHOLD:	Maximum height of <b>1/2-inch</b> ( <b>3/4-inch</b> for sliding doors).
OPENING FORCE:	1. Exterior = <b>8.5 lbf</b> 2. Interior = <b>5 lbf</b> 3. sliding = <b>5 lbf</b>
SPACE:	Provide <b>60-inch x 60-inch</b> clear approach space for doors.

### WATER FOUNTAIN

SPOUT HEIGHT:	Maximum of <b>36-inches</b> above floor surface.
---------------	--

### WATER CLOSET (TOILET)

HEIGHT:	Between <b>17-inches</b> & <b>19-inches</b> above floor surface to top of seat.
GRAB BAR:	1. Height = between <b>33-inches</b> & <b>36-inches</b> above floor. 2. Behind toilet = <b>36-inches</b> wide minimum width. 3. Beside toilet = <b>42-inches</b> long minimum. (12" off wall)
CENTER:	Center of toilet <b>18-inches</b> from wall.

### LAVATORY

HEIGHT:	Maximum <b>34-inches</b> to top of lavatory.
MIRROR:	Maximum <b>40-inches</b> to bottom of mirror.
DEPTH:	Between <b>17-inches</b> & <b>19-inches</b> to front of lavatory from wall.
FLOOR SPACE:	Minimum <b>30-inch</b> wide x <b>48-inch</b> deep space in front of lavatory.

<b>URINALS</b>	
HEIGHT:	Maximum height of <b>17-inches</b> to rim above floor.
CONTROL:	Maximum flush control height of <b>44-inches</b> above floor.

<b>TOILET ROOMS</b>	
TURNAROUND:	A minimum <b>60" x 60"</b> clear turnaround space is required in toilet room.
TOILET:	Must be located <b>18"</b> from wall to center of toilet.
	Minimum of <b>18"</b> from center of toilet to edge of lavatory
	Minimum clear space of <b>48" x 66"</b> required at toilet.
LAVATORY:	Minimum clear space of <b>30" x 48"</b> required at lavatory.
DOOR:	Minimum clear opening width of <b>32-inches</b> .
	Door <b>cannot</b> swing into clear floor space for toilet or lavatory.

<b>PARKING</b>	
<b>TOTAL PARKING SPACES</b>	<b>REQUIRED ACCESSIBLE SPACES</b>
1 to 25	1
26 to 50	2
51 to 75	3
76 to 100	4

<b>PARKING SPACES</b>	
WIDTH:	Minimum parking space width of <b>12-feet</b>
DEPTH:	Minimum parking space depth of <b>20-feet</b> .
ACCESS AISLE:	Minimum access aisle width of <b>5-feet</b> Access aisle must be diagonally striped.
ROUTE:	Minimum <b>44-inch</b> access route required in front of parking spaces.
PAINT:	Parking space must be outlined in blue paint.
SIGN:	Sign must be D. O. T. approved.
	Sign must be mounted <b>84-inches</b> above ground.
	Sign must state "PARKING BY DISABLED PERMIT ONLY".
	Sign must state penalty for illegal use.